

PUBLIC HEALTH SERVICES GOVT. OF MAHARASHTRA
DISTRICT PUBLIC HEALTH LABORATORY, AHILYANAGAR.
Old Civil Hospital Campus, Teli khunt, Ahilyanagar.

Phone:- 0241 2354038

E-mail: dphlanr@gmail.com

REPORT OF BACTERIOLOGICAL EXAMINATION OF WATER SAMPLE

Sender's Name :- SAHYADRI INTERNATIONAL SCHOOL, SHIBLAPUR, SANGAMNER, AHILYANAGAR
Address :- SAHYADRI INTERNATIONAL SCHOOL, SHIBLAPUR, SANGAMNER, AHILYANAGAR

Sender's Letter No. & Date :- 21-07-2025 (111)
Laboratory Reference No. :- 104 / 469

Date of Sample Collection :- 25-07-2025

Date of Arrival at Laboratory :- 25-07-2025

Date of Commencing Examination:- 25-07-2025

Date of Arrival at Laboratory :-		25-07-2025			
Date of Commencing Examination:-					
Sr. No.	Particulars of Water Samples	Results of Analysis			Remark
		Most Probable Number of bacteria Per 100 ml.			
		Coliforms	Thermotolerant coliforms	<u>E.coli</u>	
1	SAHYADRI INTERNATIONAL SCHOOL , SHIBLAPUR , SANGAMNER , AHILYANAGAR DRINKING WATER SAMPLE (R.O.)	0	0	0	<u>Potable</u>
Fee Rs. :- 940/-					Date:- 25-07-2025

Date:- 25-07-2025

Receipt No :- 4462253

Fee Rs. :- 940/-

Note :- Result mentioned above is/are of submitted sample only.

Results are as per sample submitted to laboratory and it assumed that it's the representative sample of whole stock.

said water can be used for drinking purpose only after proper chlorination and ascertaining it's bacteriological quality.


Remark : The

Outward No:-

1750

Date:-

28-07-2025


Junior Scientific Officer
District Public Health Laboratory
Ahilyanagar